

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Other	Other	Y/N
1	7.8	----	----		Y
2	7.8	----	----		Y
3	7.8	60.0	----		Y
4	8.2	----	----		Y
5	7.8	----	----		Y
6	8.4	----	----		Y
7	7.7	----	----		Y
8	7.7	60.0	----		Y
9	7.7	----	----		Y
10	7.6	----	----		Y
11	7.8	----	----		Y
12	7.8	----	----		Y
13	7.8	----	----		Y
14	7.8	----	----		Y
15	7.8	60.0	----		Y
16	7.8	----	----		Y
17	7.8	----	----		Y
18	8.4	----	----		Y
19	8.5	----	----		Y
20	8.5	----	----		Y
21	8.3	60.0	----		Y
22	8.6	----	----		Y
23	8.4	----	----		Y
24	8.6	----	----		Y
25	8.0	----	----		Y
26	8.7	----	----		Y
27	8.6	60.0	----		Y
28	8.6	----	----		Y
29	7.7	----	----		Y
30	7.6	----	----		Y
31	----	----	----		Y
(No=N=Excursion) Total N's					0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00214

System Name: Garden Valley Water Assn

Entry Point: EP-A

Sample Period: November 2025

Month/Year

Number of excursions during this month : 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameter as set by State:

pH	7.2	
Alk	35 mg/l	(Alkalinity)
Other	-----	
Other	-----	()

Print Name: Ryan A. Sherman

Signature: Ryan A. Sherman

Date: December 4, 2025

Send to Drinking Water Program within 10 days after end of sampling period.

OHA Drinking Water Program, P.O. Box 14350, Portland, OR 97293-0350

Phone: (971) 673-0405

Website: <http://healthoregon.org/dwp/>