



# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Other	Other	Y/N
1	8.0	----	----		Y
2	8.3	----	----		Y
3	8.3	----	----		Y
4	8.3	----	----		Y
5	8.3	----	----		Y
6	8.2	----	----		Y
7	8.0	80.0	----		Y
8	7.7	----	----		Y
9	8.2	----	----		Y
10	8.2	----	----		Y
11	8.3	80.0	----		Y
12	8.2	----	----		Y
13	8.5	----	----		Y
14	8.4	----	----		Y
15	8.4	----	----		Y
16	8.3	----	----		Y
17	8.3	60.0	----		Y
18	8.2	----	----		Y
19	8.3	----	----		Y
20	8.1	----	----		Y
21	8.1	----	----		Y
22	8.1	----	----		Y
23	8.1	----	----		Y
24	8.2	60.0	----		Y
25	8.1	----	----		Y
26	8.1	----	----		Y
27	8.0	----	----		Y
28	8.2	----	----		Y
29	8.2	----	----		Y
30	8.1	----	----		Y
31	8.1	----	----		Y
(No=N=Excursion) Total N's					<b>0</b>

<<Have minimums been met for this day?

## ENTRY POINT

**PWS ID: 41 00214**

**System Name:** Garden Valley Water Assn

**Entry Point:** EP-A

**Sample Period:** December 2025  
Month/Year

**Number of excursions during this month :** 0  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months:** \_\_\_\_\_  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

*For OHA use only*

**Minimum Water Quality Parameter as set by State:**

pH	<b>7.2</b>	
Alk	<b>35 mg/l</b>	<i>(Alkalinity)</i>
Other	-----	
Other	-----	<i>( )</i>

**Print Name:** Ryan A. Sherman

**Signature:** *Ryan A. Sherman*

**Date:** January 8, 2026