

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control/ED

ID#	Sample Location	рΗ	Alk	PO4	other	Y/N	<has 0.9="" 2023<="" feb="" sample="" th=""></has>
5	58475 Little Cr.D	7.2	4			y	met the minimums? DISTRIBUTION Water Services
							PWS ID: 41 0 0 2 1 4
							System Name: Garden Valley WTR
							Sample Period: Jan-2023 Month/Year
							Sample Frequency: 6 months
							Distribution Samples required: 1
							Number of excursions during this Sample Period = <u>0</u>
							(Number of locations when any WQP was less than the minimum.)
							Note: Entry Point and Distribution
							Excursions are cumulative. Add Entry
							Point and Distribution Excursions to get total for sample period.
							For OHA use only
							Minimum Water Quality Parameters as set by
							pH 7.2
							Alk 35.0 (Alkalinity)
							PO4 N/A (Orthophosphate)
							Other N/A ()
						× ×	Print Name: Stephen Pennington
(N = No = Excursion) Total N's							Signature: Steph & Penkent
							Date: Fch 3 dow3

Send to Drinking Water Program within 10 days after end of sampling period: OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/