

City of Corvallis



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.2	34			Y
2	7.2				Y
3	7.2				Y
4	7.2	25			Y
5	7.2				Y
6	7.3				Y
7	7.3				Y
8	7.3				Y
9	7.3				Y
10	7.2	31			Y
11	7.3	34			Y
12	7.3				Y
13	7.2				Y
14	7.2	32			Y
15	7.3				Y
16	7.2				Y
17	7.2	32			Y
18	7.3				Y
19	7.2				Y
20	7.2	32			Y
21	7.2				Y
22	7.2				Y
23	7.2				Y
24	7.2	30			Y
25	7.2				Y
26	7.2	31			Y
27	7.2				Y
28	7.2				Y
29	7.2	35			Y
30	7.2				Y

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 2 2 5 A

System Name: TAYLOR WATER TREATMENT PLANT
Entry Point: EP-A
Sample Period: June/2021
 Month/Year

Number of excursions* during this mon 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 mont 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk	25	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Tom Hubbard

Signature:

Date: 7-7-21

(No = N = Excursion) **Total N's** 0

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381