

City of Corvallis



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Sili | Y/N |
|-----|-----|-----|------|------|-----|
| 1 | 7.2 | 37 | | | Y |
| 2 | 7.2 | 36 | | | Y |
| 3 | 7.2 | 38 | | | Y |
| 4 | 7.2 | 37 | | | Y |
| 5 | 7.2 | 36 | | | Y |
| 6 | 7.3 | 36 | | | Y |
| 7 | 7.2 | 37 | | | Y |
| 8 | 7.2 | 33 | | | Y |
| 9 | 7.2 | 33 | | | Y |
| 10 | 7.2 | 32 | | | Y |
| 11 | 7.2 | 38 | | | Y |
| 12 | 7.2 | 36 | | | Y |
| 13 | 7.2 | 34 | | | Y |
| 14 | 7.2 | 32 | | | Y |
| 15 | 7.2 | 32 | | | Y |
| 16 | 7.2 | 32 | | | Y |
| 17 | 7.2 | 37 | | | Y |
| 18 | 7.2 | 37 | | | Y |
| 19 | 7.3 | 33 | | | Y |
| 20 | 7.1 | 35 | | | Y |
| 21 | 7.2 | 34 | | | Y |
| 22 | 7.2 | 39 | | | Y |
| 23 | 7.2 | 39 | | | Y |
| 24 | 7.3 | 36 | | | Y |
| 25 | 7.3 | 38 | | | Y |
| 26 | 7.3 | 32 | | | Y |
| 27 | 7.2 | 33 | | | Y |
| 28 | 7.2 | 38 | | | Y |

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 2 2 5 A

System Name: TAYLOR WATER TREATMENT PLANT
Entry Point: EP-A
Sample Period: February/2022
 Month/Year

Number of excursions* during this mon 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 mont 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by

| | | |
|------|-----|------------------|
| pH | 7.0 | |
| Alk | 25 | (Alkalinity) |
| PO4 | | (Orthophosphate) |
| Sili | | (Silicate) |

(No = N = Excursion) **Total N's** 0

Print Name: Chad Marshall
Signature: *Chad Marshall*
Date: 3/4/2022