

# City of Corvallis



Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.2	36			Y
2	7.2	33			Y
3	7.2	34			Y
4	7.2	34			Y
5	7.2	36			Y
6	7.2	34			Y
7	7.2	36			Y
8	7.2	38			Y
9	7.3	39			Y
10	7.3	36			Y
11	7.2	35			Y
12	7.2	34			Y
13	7.2	34			Y
14	7.3	33			Y
15	7.3	36			Y
16	7.3	38			Y
17	7.3	36			Y
18	7.3	38			Y
19	7.3	35			Y
20	7.3	35			Y
21	7.3	35			Y
22	7.3	33			Y
23	7.4	35			Y
24	7.3	37			Y
25					Y
26	7.3	33			Y
27	7.3	32			Y
28	7.2	35			Y
29	7.2	35			Y
30	7.2	35			Y
31	7.2	32			Y

<< Have minimums been met for this day?

### ENTRY POINT

PWS ID: 41      A

**System Name:** TAYLOR WATER TREATMENT PLANT  
**Entry Point:** EP-A  
**Sample Period:** December/2022  
 Month/Year

Number of excursions\* during this mon 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 mont 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

#### Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.0"/>	
Alk	<input type="text" value="25"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Sili	<input type="text"/>	(Silicate)

**Print Name:** Chad Marshall

**Signature:** *Chad Marshall*

**Date:** 1-9-2023

(No = N = Excursion) Total N's

Send to DHS within 10 days after end of sampling period