

# City of Corvallis



## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.2	31			Y
2	7.2	32			Y
3	7.2				Y
4	7.2	37			Y
5	7.2	34			Y
6	7.2	32			Y
7	7.2	36			Y
8	7.2	37			Y
9	7.2				Y
10	7.2				Y
11	7.2	38			Y
12	7.2	36			Y
13	7.2	37			Y
14	7.2	39			Y
15	7.2	39			Y
16	7.2	38			Y
17	7.2	39			Y
18	7.2	37			Y
19	7.2	36			Y
20	7.2	38			Y
21	7.3	36			Y
22	7.3	36			Y
23	7.2	38			Y
24	7.2	37			Y
25	7.2	36			Y
26	7.2	39			Y
27	7.2	36			Y
28	7.2	38			Y
29	7.2	35			Y
30	7.2	37			Y
31	7.2	36			Y

(No = N = Excursion) **Total N's** 0

<< Have minimums been met for this day?

### ENTRY POINT

PWS ID: 41 0 0 2 2 5 A

**System Name:** TAYLOR WATER TREATMENT PLANT  
**Entry Point:** EP-A  
**Sample Period:** March/2023  
 Month/Year

**Number of excursions\* during this mon** 0

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 mont** 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

#### Minimum Water Quality Parameters as set by

pH	7.0	
Alk	25	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

**Print Name:** Chad Marshall  
**Signature:** *Chad Marshall*  
**Date:** 4-7-2023

Send to DHS within 10 days after end of sampling period