

City of Corvallis



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.3	36			Y
2	7.3	38			Y
3	7.2	40			Y
4	7.2	37			Y
5	7.2	36			Y
6	7.2	37			Y
7	7.2	36			Y
8	7.2	38			Y
9	7.2	37			Y
10	7.3	36			Y
11	7.2	35			Y
12	7.2	37			Y
13	7.2	36			Y
14	7.2	38			Y
15	7.2	36			Y
16	7.2	35			Y
17	7.2	37			Y
18	7.2	38			Y
19	7.2	37			Y
20	7.2	36			Y
21	7.2	39			Y
22	7.2	36			Y
23	7.2	35			Y
24	7.2	34			Y
25	7.2	37			Y
26	7.2	36			Y
27	7.2	37			Y
28	7.2	38			Y
29	7.2	37			Y
30	7.2	37			Y

(No = N = Excursion) **Total N's** 0

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 2 2 5 A

System Name: TAYLOR WATER TREATMENT PLANT
Entry Point: EP-A
Sample Period: April/2023
 Month/Year

Number of excursions* during this mon 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 mont 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk	25	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Chad Marshall
Signature: *Chad Marshall*
Date: 5-5-23

Send to DHS within 10 days after end of sampling period