

# City of Corvallis



Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.2	32			Y
2	7.2				Y
3	7.2	32			Y
4	7.2				Y
5	7.3	30			Y
6	7.2				Y
7	7.2	30			Y
8	7.2				Y
9	7.2	31			Y
10	7.2				Y
11	7.2	32			Y
12	7.2				Y
13	7.2	26			Y
14	7.2				Y
15	7.2	30			Y
16	7.2				Y
17	7.2	32			Y
18	7.3				Y
19	7.2	30			Y
20	7.2				Y
21	7.3				Y
22	7.3	30			Y
23	7.2				Y
24	7.2	30			Y
25	7.2				Y
26	7.2	33			Y
27	7.2				Y
28	7.2	34			Y
29	7.2				Y
30	7.2	30			Y

(No = N = Excursion) **Total N's** 0

<< Have minimums been met for this day?

### ENTRY POINT

PWS ID: 41 0 0 2 2 5 A

**System Name:** TAYLOR WATER TREATMENT PLANT  
**Entry Point:** EP-A  
**Sample Period:** June/2023  
 Month/Year

**Number of excursions\* during this mon** 0

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 mont** 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

#### Minimum Water Quality Parameters as set by

pH	7.0	
Alk	25	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

**Print Name:** Chad Marshall

**Signature:** *Chad Marshall*

**Date:** 7/5/2023

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381