

# City of Corvallis



## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.3				Y
2	7.3	30			Y
3	7.3				Y
4	7.3	32			Y
5	7.3				Y
6	7.3	31			Y
7	7.3				Y
8	7.3	31			Y
9	7.3				Y
10	7.3	31			Y
11	7.3				Y
12	7.4	32			Y
13	7.3				Y
14	7.3	34			Y
15	7.3				Y
16	7.3	33			Y
17	7.3				Y
18	7.3	30			Y
19	7.3				Y
20	7.3	33			Y
21	7.3				Y
22	7.3	32			Y
23	7.4				Y
24	7.4	32			Y
25	7.4				Y
26	7.3	30			Y
27	7.3				Y
28	7.3	30			Y
29	7.3				Y
30	7.3	35			Y

<< Have minimums been met for this day?

### ENTRY POINT

PWS ID: 41      A

**System Name:** TAYLOR WATER TREATMENT PLANT  
**Entry Point:** EP-A  
**Sample Period:** September/2023  
 Month/Year

Number of excursions\* during this mon 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 mont 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

#### Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.0"/>	
Alk	<input type="text" value="25"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Sili	<input type="text"/>	(Silicate)

Print Name: Chad Marshall

Signature: *Chad Marshall*

Date: 10/9/2023

(No = N = Excursion) Total N's

Send to DHS within 10 days after end of sampling period