

City of Corvallis



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.3	33			Y
2	7.3	34			Y
3	7.4	34			Y
4	7.3	33			Y
5	7.3	36			Y
6	7.4	36			Y
7	7.4	37			Y
8	7.3	36			Y
9	7.4	36			Y
10	7.4	35			Y
11	7.4	36			Y
12	7.4	36			Y
13	7.3	37			Y
14	7.3	36			Y
15	7.3	38			Y
16	7.4	35			Y
17	7.4	33			Y
18	7.4	35			Y
19	7.3	33			Y
20	7.3	34			Y
21	7.3	34			Y
22	7.3	34			Y
23	7.4	34			Y
24	7.3	34			Y
25	7.4	32			Y
26	7.4	35			Y
27	7.4	36			Y
28	7.4	36			Y
29	7.4	33			Y
30	7.4	33			Y

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 A

System Name: TAYLOR WATER TREATMENT PLANT
Entry Point: EP-A
Sample Period: November/2023
 Month/Year

Number of excursions* during this mon 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 mont 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.0"/>	
Alk	<input type="text" value="25"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Sili	<input type="text"/>	(Silicate)

Print Name: Chad Marshall
Signature: *Chad Marshall*
Date: 12/7/2023

(No = N = Excursion) **Total N's**

Send to DHS within 10 days after end of sampling period