

City of Corvallis



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.3	33			Y
2	7.3	33			Y
3	7.2	34			Y
4	7.2				Y
5	7.3	35			Y
6	7.3	34			Y
7	7.3	36			Y
8	7.3	34			Y
9	7.3	34			Y
10	7.4	38			Y
11	7.4	36			Y
12	7.5	33			Y
13	7.3	32			Y
14	7.2	36			Y
15	7.2	36			Y
16	7.2	37			Y
17	7.3	38			Y
18	7.3	44			Y
19	7.2	40			Y
20	7.2	42			Y
21	7.2	41			Y
22	7.2	39			Y
23	7.3	40			Y
24	7.2	38			Y
25	7.2	38			Y
26	7.2	38			Y
27	7.3	38			Y
28	7.3	38			Y
29	7.3	37			Y

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 A

System Name: TAYLOR WATER TREATMENT PLANT
Entry Point: EP-A
Sample Period: February/2024
 Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	<input type="text" value="7.0"/>	
Alk	<input type="text" value="25"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Sili	<input type="text"/>	(Silicate)

(No = N = Excursion) Total N's

Print Name: Chad Marshall

Signature: *Chad Marshall*

Date: 3/5/2024

Send to DHS within 10 days after end of sampling period