

City of Corvallis



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Other | Y/N | |
|----------------------|-----|-----|------|-------|------------------|----------|
| 1 | 7.2 | 39 | | | Y | |
| 2 | 7.3 | 39 | | | Y | |
| 3 | 7.3 | 40 | | | Y | |
| 4 | 7.3 | 42 | | | Y | |
| 5 | 7.3 | 40 | | | Y | |
| 6 | 7.3 | 38 | | | Y | |
| 7 | 7.3 | 40 | | | Y | |
| 8 | 7.2 | 37 | | | Y | |
| 9 | 7.2 | 37 | | | Y | |
| 10 | 7.2 | 39 | | | Y | |
| 11 | 7.3 | 40 | | | Y | |
| 12 | 7.3 | 37 | | | Y | |
| 13 | 7.3 | 38 | | | Y | |
| 14 | 7.3 | 38 | | | Y | |
| 15 | 7.3 | 40 | | | Y | |
| 16 | 7.3 | 40 | | | Y | |
| 17 | 7.3 | 40 | | | Y | |
| 18 | 7.3 | 37 | | | Y | |
| 19 | 7.3 | 38 | | | Y | |
| 20 | 7.3 | 36 | | | Y | |
| 21 | 7.3 | 34 | | | Y | |
| 22 | 7.3 | 34 | | | Y | |
| 23 | 7.3 | 36 | | | Y | |
| 24 | 7.3 | 38 | | | Y | |
| 25 | 7.3 | 33 | | | Y | |
| 26 | 7.3 | 34 | | | Y | |
| 27 | 7.3 | 38 | | | Y | |
| 28 | 7.3 | 38 | | | Y | |
| 29 | 7.3 | 40 | | | Y | |
| 30 | 7.3 | 38 | | | Y | |
| 31 | 7.3 | 33 | | | Y | |
| (No = N = Excursion) | | | | | Total N's | 0 |

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

A

System Name:

TAYLOR WATER TREATMENT PLANT

Entry Point:

EP-A

Sample Period:

March/2024

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

--- For DHS use only ---

Minimum Water Quality Parameters as set by

| | | |
|------|----------------------------------|------------------|
| pH | <input type="text" value="7.0"/> | |
| Alk | <input type="text" value="25"/> | (Alkalinity) |
| PO4 | <input type="text"/> | (Orthophosphate) |
| Sili | <input type="text"/> | (Silicate) |

Print Name:

Chad Marshall

Signature:

Chad Marshall

Date:

4/08/2024