

City of Corvallis



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.2				Y
2	7.3	30			Y
3	7.2				Y
4	7.3	30			Y
5	7.2				Y
6	7.2	31			Y
7	7.2				Y
8	7.3	30			Y
9	7.3				Y
10	7.3	30			Y
11	7.3				Y
12	7.3	33			Y
13	7.3				Y
14	7.3	32			Y
15	7.3				Y
16	7.3	31			Y
17	7.3				Y
18	7.3	32			Y
19	7.3				Y
20	7.3	32			Y
21	7.3				Y
22	7.3	33			Y
23	7.3				Y
24	7.3	32			Y
25	7.3				Y
26	7.3	31			Y
27	7.3				Y
28	7.3	31			Y
29	7.3				Y
30	7.2	32			Y
31	7.2				Y
(No = N = Excursion)					Total N's 0

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0 0 2 2 5 A

System Name:

TAYLOR WATER TREATMENT PLANT

Entry Point:

EP-A

Sample Period:

July/2024

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

--- For DHS use only ---

Minimum Water Quality Parameters as set by

pH	7.0	
Alk	25	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name:

Chad Marshall

Signature:

Chad Marshall

Date:

8/5/2024

Send to DHS within 10 days after end of sampling period
 DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381