

City of Corvallis



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3	33			Y
2	7.3				Y
3	7.3	30			Y
4	7.3				Y
5	7.3	30			Y
6	7.3				Y
7	7.3	33			Y
8	7.3				Y
9	7.3	36			Y
10	7.3				Y
11	7.4	31			Y
12	7.3				Y
13	7.3	31			Y
14	7.4				Y
15	7.3	30			Y
16	7.3				Y
17	7.3	30			Y
18	7.3				Y
19	7.3	31			Y
20	7.4				Y
21	7.4	31			Y
22	7.4				Y
23	7.3	31			Y
24	7.3				Y
25	7.3	32			Y
26	7.3				Y
27	7.4	30			Y
28	7.3				Y
29	7.4	30			Y
30	7.4				Y
31	7.3	32			Y
(No = N = Excursion)					Total N's 0

<< Have
minimums
been met
for this day?

ENTRY POINT

PWS ID: 41

0 0 2 2 5 A

System Name:

TAYLOR WATER TREATMENT PLANT

Entry Point:

EP-A

Sample Period:

July/2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

--- For DHS use only ---

Minimum Water Quality
Parameters as set by

pH 7.0

Alk 25 (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name:

Signature:

Date:

Chad Marshall
Chad Marshall
8/4/2025

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381