

City of Corvallis



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3	34			Y
2	7.3	35			Y
3	7.3	34			Y
4	7.3	38			Y
5	7.4	37			Y
6	7.3	36			Y
7	7.3	38			Y
8	7.3	37			Y
9	7.3	36			Y
10	7.3	36			Y
11	7.3	35			Y
12	7.3	36			Y
13	7.3	39			Y
14	7.3	39			Y
15	7.3	42			Y
16	7.2	40			Y
17	7.3	38			Y
18	7.3	38			Y
19	7.3	40			Y
20	7.3	44			Y
21	7.3	42			Y
22	7.3	42			Y
23	7.2	41			Y
24	7.3	42			Y
25	7.2	42			Y
26	7.2	40			Y
27	OFF				
28	7.2	39			Y
29	7.3	40			Y
30	7.3	39			Y

(No = N = Excursion)

Total N's

0

<< Have
minimums
been met
for this day?

PWS ID: 41

0 0 2 2 5 A

ENTRY POINT

System Name: TAYLOR WATER TREATMENT PLANT

Entry Point: EP-A

Sample Period: November/2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less
than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

---- For DHS use only ----

Minimum Water Quality
Parameters as set by

pH 7.0

Alk 25

(Alkalinity)

PO4

(Orthophosphate)

Sili

(Silicate)

Print Name:

Chad Marshall

Signature:

Chad Marshall
12/4/25

Date:

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381