

City of Corvallis

Water Quality Parameter Monitoring Form



Lead & Copper Rule Corrosion Control

ENTRY POINT

Day	pH	Alk	Phos	Other	Y/N
1	7.2	36			Y
2	7.3	38			Y
3	7.2	36			Y
4	7.2	36			Y
5	7.2	35			Y
6	7.2	37			Y
7	7.3	36			Y
8	7.4	38			Y
9	7.4	38			Y
10	7.4	40			Y
11	7.4	40			Y
12	7.3	37			Y
13	7.3	36			Y
14	7.3	35			Y
15	7.3	40			Y
16	7.3	40			Y
17	7.3	40			Y
18	7.3	40			Y
19	7.2	39			Y
20	7.2	38			Y
21	7.3	40			Y
22	7.2	36			Y
23	7.3	34			Y
24	7.2	34			Y
25	OFF				
26	7.4	40			Y
27	7.4	38			Y
28	7.4	40			Y
29	7.3	36			Y
30	7.3	36			Y
31	7.4	36			Y
Total N's					0

(No = N = Excursion)

<< Have minimums been met for this day?

PWS ID: 41

0 0 2 2 5 A

System Name:

TAYLOR WATER TREATMENT PLANT

Entry Point:

EP-A

Sample Period:

December/2025
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

---- For DHS use only ----

Minimum Water Quality Parameters as set by

pH 7.0

Alk 25 (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name:

Signature:

Date:

Chad Marshall
Ch Marshall
1/2/2026

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381