

City of Corvallis

Water Quality Parameter Monitoring Form



Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N	
1	OFF					
2	7.3	35			Y	
3	7.2	36			Y	
4	7.3	38			Y	
5	7.2	37			Y	
6	7.3	37			Y	
7	7.2	34			Y	
8	7.2	34			Y	
9	7.2	34			Y	
10	7.3	34			Y	
11	7.2	33			Y	
12	7.2	34			Y	
13	7.2	33			Y	
14	7.3	36			Y	
15	7.3	34			Y	
16	7.3	36			Y	
17	7.3	36			Y	
18	7.3	35			Y	
19	OFF					
20	7.2	36			Y	
21	7.2	38			Y	
22	7.3	34			Y	
23	7.2	34			Y	
24	7.2	37			Y	
25	7.2	36			Y	
26	7.2	36			Y	
27	7.2	38			Y	
28	7.3	35			Y	
29	7.2	37			Y	
30	7.3	39			Y	
31	7.3	36			Y	
(No = N = Excursion)					Total N's	0

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

A

System Name:

TAYLOR WATER TREATMENT PLANT

Entry Point:

EP-A

Sample Period:

January/2026

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

--- For DHS use only ---

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.0"/>	
Alk	<input type="text" value="25"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Sili	<input type="text"/>	(Silicate)

Print Name:

Signature:

Date:

Chad Marshall
Chad Marshall
2/6/26

Send to DHS within 10 days after end of sampling period
 DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381