

# City of Corvallis

Water Quality Parameter Monitoring Form



## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3	38			Y
2	7.2	37			Y
3	7.2	38			Y
4	7.2	38			Y
5	7.2	37			Y
6	7.2	35			Y
7	7.2	38			Y
8	7.2	38			Y
9	7.2	38			Y
10	7.2	39			Y
11	7.2	41			Y
12	7.2	40			Y
13	7.2	39			Y
14	7.2	35			Y
15	7.2	35			Y
16	OFF				
17	7.3	38			Y
18	7.3	40			Y
19	7.3	40			Y
20	7.2	35			Y
21	7.2	37			Y
22	7.2	35			Y
23	7.2	38			Y
24	7.2	38			Y
25	7.2	39			Y
26	7.1	37			Y
27	7.2	36			Y
28	7.2	40			Y
<b>Total N's</b>					<b>0</b>

(No = N = Excursion)

<< Have minimums been met for this day?

PWS ID: 41      0   0   2   2   5   A

### ENTRY POINT

**System Name:** TAYLOR WATER TREATMENT PLANT  
**Entry Point:** EP-A  
**Sample Period:** February/2026  
 Month/Year

**Number of excursions\* during this month:** 0  
 (Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

---- For DHS use only ----

**Minimum Water Quality Parameters as set by**

pH    7.0  
 Alk    25    (Alkalinity)  
 PO4         (Orthophosphate)  
 Sili         (Silicate)

**Print Name:**

**Signature:**

**Date:**

*Chad Marshall*  
*[Signature]*  
 3/9/26