

# City of Corvallis



## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.2				Y
2	7.3				Y
3	7.3	38			Y
4	7.4				Y
5	7.4				Y
6	7.3				Y
7	7.4				Y
8	7.4				Y
9	7.3				Y
10	7.3				Y
11	7.3				Y
12	7.2				Y
13	7.1				Y
14	7.3				Y
15	7.3				Y
16	7.2				Y
17	7.3				Y
18	7.3				Y
19	7.3	38			Y
20	7.3				Y
21	7.4				Y
22	7.4				Y
23	7.4				Y
24	7.4	38			Y
25	7.4				Y
26	7.3				Y
27	7.3				Y
28	7.4				Y

(No = N = Excursion) **Total N's** 0

<< Have minimums been met for this day?

### ENTRY POINT

PWS ID: 41 0 0 2 2 5 B

**System Name:** ROCK CREEK WATER TREATMENT PLANT  
**Entry Point:** EP-B  
**Sample Period:** February/2021  
 Month/Year

Number of excursions\* during this month 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

#### Minimum Water Quality Parameters as set by

pH	7.0	
Alk	37.3	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Tom Hubbard

Signature: [Signature]

Date: 3-5-2021