

City of Corvallis



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.4				Y
2	7.3				Y
3	7.3	41			Y
4	7.3				Y
5	7.3				Y
6	7.3				Y
7	7.3				Y
8	7.3				Y
9	7.4				Y
10	7.3	44			Y
11	7.3				Y
12	7.4				Y
13	7.4				Y
14	7.4				Y
15	7.3				Y
16	7.4				Y
17	7.3				Y
18	7.3	41			Y
19	7.3				Y
20	7.3				Y
21	7.3				Y
22	7.3				Y
23	7.3				Y
24	7.3	44			Y
25	7.3				Y
26	7.2				Y
27	7.3				Y
28	7.3				Y
29	7.3				Y
30	7.4				Y

(No = N = Excursion)

Total N's 0

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0 0 2 2 5 B

System Name: ROCK CREEK WATER TREATMENT PLANT

Entry Point: EP-B

Sample Period: April/2021
Month/Year

Number of excursions* during this mon 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 mont 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk	37.3	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Tom Hubbard

Signature:

Date: 5-5-21

Send to DHS within 10 days after end of sampling period