

City of Corvallis



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1 | 7.5 | | | | Y |
| 2 | 7.5 | | | | Y |
| 3 | 7.4 | | | | Y |
| 4 | 7.4 | | | | Y |
| 5 | 7.4 | | | | Y |
| 6 | 7.4 | 44 | | | Y |
| 7 | 7.4 | | | | Y |
| 8 | 7.2 | | | | Y |
| 9 | 7.2 | | | | Y |
| 10 | 7.2 | | | | Y |
| 11 | 7.2 | | | | Y |
| 12 | 7.2 | | | | Y |
| 13 | 7.2 | 41 | | | Y |
| 14 | 7.2 | | | | Y |
| 15 | 7.2 | 44 | | | Y |
| 16 | 7.3 | | | | Y |
| 17 | 7.3 | | | | Y |
| 18 | 7.3 | | | | Y |
| 19 | 7.2 | | | | Y |
| 20 | 7.2 | | | | Y |
| 21 | 7.2 | | | | Y |
| 22 | 7.2 | | | | Y |
| 23 | 7.3 | 46 | | | Y |
| 24 | 7.3 | | | | Y |
| 25 | 7.2 | | | | Y |
| 26 | 7.2 | | | | Y |
| 27 | 7.2 | | | | Y |
| 28 | 7.2 | | | | Y |
| 29 | 7.2 | | | | Y |
| 30 | 7.2 | | | | Y |
| 31 | 7.1 | 42 | | | Y |

(No = N = Excursion)

Total N's 0

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 2 2 5 B

System Name: ROCK CREEK WATER TREATMENT PLANT

Entry Point: EP-B

Sample Period: July/2021
Month/Year

Number of excursions* during this mon 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 mont 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by

| | | |
|------|-----|------------------|
| pH | 7.0 | |
| Alk | 36 | (Alkalinity) |
| PO4 | | (Orthophosphate) |
| Sili | | (Silicate) |

Print Name: Chad Marshall

Signature: *Chad Marshall*

Date: 8-3-2021

Send to DHS within 10 days after end of sampling period