

City of Corvallis



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.6	44			Y
2	7.6				Y
3	7.7				Y
4	7.7				Y
5	7.6				Y
6	7.6				Y
7	7.5				Y
8	7.6	40			Y
9	7.6				Y
10	7.5				Y
11	7.4				Y
12	7.5				Y
13	7.5				Y
14	7.5				Y
15	7.6	42			Y
16	7.6				Y
17	7.6				Y
18	7.7				Y
19	7.7				Y
20	7.7				Y
21	7.7				Y
22	7.8	40			Y
23	7.8				Y
24	7.8				Y
25	7.8				Y
26	7.8				Y
27	7.8				Y
28	7.9				Y
29	7.9				Y
30	7.6	40			Y
31	7.5				Y

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 2 2 5 B

System Name: ROCK CREEK WATER TREATMENT PLANT

Entry Point: EP-B

Sample Period: December/2021
Month/Year

Number of excursions* during this mon 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 mont 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk	36	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Chad Marshall

Signature: *Chad Marshall*

Date: 1-5-2022

(No = N = Excursion) Total N's 0

Send to DHS within 10 days after end of sampling period