

# City of Corvallis



## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.2	40			Y
2	7.3				Y
3	7.2				Y
4	7.2				Y
5	7.2				Y
6	7.2				Y
7	7.2				Y
8	7.2	49			Y
9	7.3				Y
10	7.2				Y
11	7.3				Y
12	7.3				Y
13	7.3				Y
14	7.3				Y
15	7.3	41			Y
16	7.4				Y
17	7.3				Y
18	7.2				Y
19	7.2				Y
20	7.1				Y
21	7.2				Y
22	7.1	41			Y
23	7.1				Y
24	7.1				Y
25	7.2				Y
26	7.2				Y
27	7.3				Y
28	7.2				Y
29	7.2	40			Y
30	7.3				Y
31	7.2				Y

(No = N = Excursion) **Total N's** 0

<< Have minimums been met for this day?

### ENTRY POINT

PWS ID: 41 0 0 2 2 5 **B**

**System Name:** ROCK CREEK WATER TREATMENT PLANT

**Entry Point:** EP-B

**Sample Period:** March/2023  
Month/Year

**Number of excursions\* during this mon** 0  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 mont** 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

**Minimum Water Quality Parameters as set by**

pH	7.0	
Alk	36	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

**Print Name:** Chad Marshall

**Signature:**

**Date:** 4-7-2023