

# City of Corvallis



Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.4				Y
2	7.4				Y
3	7.3	43			Y
4	7.3				Y
5	7.3				Y
6	7.2				Y
7	7.3				Y
8	7.3				Y
9	7.2				Y
10	7.3	40			Y
11	7.4				Y
12	7.3				Y
13	7.3				Y
14	7.3				Y
15	7.3				Y
16	7.3				Y
17	7.3	40			Y
18	7.3				Y
19	7.4				Y
20	7.4				Y
21	7.3				Y
22	7.2				Y
23	7.3				Y
24	7.3	40			Y
25	7.3				Y
26	7.3				Y
27	7.2				Y
28	7.4				Y
29	7.4				Y
30	7.4				Y
31	7.4	43			Y

(No = N = Excursion) **Total N's** 0

<< Have minimums been met for this day?

### ENTRY POINT

PWS ID: 41 0 0 2 2 5 B

**System Name:** ROCK CREEK WATER TREATMENT PLANT

**Entry Point:** EP-B

**Sample Period:** January/2024  
Month/Year

**Number of excursions\* during this month:** 0

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months:** 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

#### Minimum Water Quality Parameters as set by State:

pH	7.0	
Alk	36	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

**Print Name:** Chad Marshall

**Signature:** *Chad Marshall*

**Date:** 2/7/2024

Send to DHS within 10 days after end of sampling period