

City of Corvallis



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.4				Y
2	7.3				Y
3	7.2				Y
4	7.3				Y
5	7.3				Y
6	7.2				Y
7	7.2	40			Y
8	7.2				Y
9	7.2				Y
10	7.3				Y
11	7.3				Y
12	7.4				Y
13	7.4				Y
14	7.3	42			Y
15	7.3				Y
16	7.3				Y
17	7.4				Y
18	7.3				Y
19	7.3				Y
20	7.3	40			Y
21	7.2				Y
22	7.2				Y
23	7.3				Y
24	7.4				Y
25	7.4				Y
26	7.3				Y
27	7.3				Y
28	7.4	40			Y
29	7.4				Y

(No = N = Excursion)

Total N's **0**

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 **0 0 2 2 5** B

System Name: ROCK CREEK WATER TREATMENT PLANT

Entry Point: EP-B

Sample Period: February/2024
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by State:

pH	7.0	
Alk	36	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Chad Marshall

Signature: *Chad Marshall*

Date: 3/5/2024

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381