

City of Corvallis

Water Quality Parameter Monitoring Form



Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N	
1	7.3				Y	
2	7.3				Y	
3	7.4				Y	
4	7.3	43			Y	
5	7.3				Y	
6	7.3				Y	
7	7.3				Y	
8	7.3				Y	
9	7.3	42			Y	
10	7.3				Y	
11	7.3				Y	
12	7.3				Y	
13	7.3				Y	
14	7.2				Y	
15	7.1				Y	
16	7.2				Y	
17	7.2	44			Y	
18	7.2				Y	
19	7.2				Y	
20	7.2				Y	
21	7.2				Y	
22	7.2				Y	
23	7.2				Y	
24	7.2	45			Y	
25	7.2				Y	
26	7.2				Y	
27	7.2				Y	
28	7.2				Y	
29	7.2				Y	
30	7.2				Y	
31	7.1	48			Y	
(No = N = Excursion)					Total N's	0

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0 0 2 2 5 B

System Name:

ROCK CREEK WATER TREATMENT PLANT

Entry Point:

EP-B

Sample Period:

July/2024

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

--- For DHS use only ---

Minimum Water Quality Parameters as set by

pH	7.0	
Alk	36	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name:

Signature:

Date:

Chad Marshall

 8/5/2024

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381