

City of Corvallis

Water Quality Parameter Monitoring Form



Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.2				Y
2	7.2				Y
3	7.2				Y
4	7.2	48			Y
5	7.3				Y
6	7.3				Y
7	7.3				Y
8	7.3				Y
9	OFF				
10	OFF				
11	OFF				
12	7.2				Y
13	7.2				Y
14	7.2	47			Y
15	7.2				Y
16	7.2				Y
17	7.2				Y
18	7.2	48			Y
19	7.2				Y
20	7.2				Y
21	7.2				Y
22	7.2				Y
23	7.2				Y
24	7.3				Y
25	7.2	50			Y
26	7.2				Y
27	7.3				Y
28	7.3				Y
29	7.3				Y
30	7.4				Y
(No = N = Excursion)					Total N's 0

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0 0 2 2 5 B

System Name:

ROCK CREEK WATER TREATMENT PLANT

Entry Point:

EP-B

Sample Period:

September/2024

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

--- For DHS use only ---

Minimum Water Quality Parameters as set by

pH	7.0	
Alk	36	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name:

Chad Marshall

Signature:

Chad Marshall

Date:

10/4/2024

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381