

City of Corvallis

Water Quality Parameter Monitoring Form



Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5				Y
2	7.5	40			Y
3	7.5				Y
4	7.4				Y
5	7.4				Y
6	7.5				Y
7	7.5				Y
8	7.6	41			Y
9	7.6				Y
10	7.6				Y
11	7.6				Y
12	7.7				Y
13	7.7				Y
14	7.7				Y
15	7.8	40			Y
16	7.8				Y
17	7.7				Y
18	7.8				Y
19	7.8				Y
20	7.7				Y
21	7.7				Y
22	7.7	40			Y
23	7.8				Y
24	7.8				Y
25	7.5	42			Y
26	7.4				Y
27	7.5	40			Y
28	7.5				Y
29	7.6	40			Y
30	7.4				Y
31	7.3				Y
(No = N = Excursion)					Total N's 0

<< Have
minimums
been met
for this day?

ENTRY POINT

PWS ID: 41

0

0

2

2

5

B

System Name:

ROCK CREEK WATER TREATMENT PLANT

Entry Point:

EP-B

Sample Period:

January/2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

---- For DHS use only ----

Minimum Water Quality Parameters as set by

pH	7.0	
Alk	36	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name:

Signature:

Date:

Chad Marshall
Chad Marshall
2/4/2025

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381