

City of Corvallis

Water Quality Parameter Monitoring Form



Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.4				Y
2	7.4				Y
3	7.4				Y
4	7.4				Y
5	7.4				Y
6	7.4				Y
7	7.4	41			Y
8	7.4				Y
9	7.5				Y
10	7.4				Y
11	7.4				Y
12	7.4				Y
13	7.3				Y
14	7.3				Y
15	7.3	40			Y
16	7.3				Y
17	7.3				Y
18	7.3				Y
19	7.2				Y
20	7.2				Y
21	7.2	41			Y
22	7.2				Y
23	7.2				Y
24	7.2				Y
25	7.2				Y
26	7.2				Y
27	7.2				Y
28	7.2	42			Y
29	7.2				Y
30	7.2				Y
31	7.2				Y
(No = N = Excursion)					Total N's 0

<< Have
minimums
been met
for this day?

ENTRY POINT

PWS ID: 41

0

0

2

2

5

B

System Name:

ROCK CREEK WATER TREATMENT PLANT

Entry Point:

EP-B

Sample Period:

May/2025

Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

--- For DHS use only ---

Minimum Water Quality
Parameters as set by

pH 7.0

Alk 36

PO4

Sili

(Alkalinity)

(Orthophosphate)

(Silicate)

Print Name:

Signature:

Date:

Chad Marshall
Chad Marshall
6/5/25

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381