

City of Corvallis

Water Quality Parameter Monitoring Form



Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.2				Y
2	7.2	43			Y
3	7.2				Y
4	7.2				Y
5	7.1				Y
6	7.1				Y
7	7.1				Y
8	7.1				Y
9	7.2	46			Y
10	7.1				Y
11	7.1				Y
12	7.1				Y
13	7.1				Y
14	7.1				Y
15	7.2				Y
16	7.1	46			Y
17	7.1				Y
18	7.2				Y
19	7.1				Y
20	7.2				Y
21	7.2				Y
22	7.1				Y
23	7.2	46			Y
24	7.2				Y
25	7.2				Y
26	7.1				Y
27	7.1				Y
28	7.1				Y
29	7.2				Y
30	7.2				Y
31	7.2				Y
(No = N = Excursion)					Total N's 0

<< Have
minimums
been met
for this day?

ENTRY POINT

PWS ID: 41 0 0 2 2 5 B

System Name: ROCK CREEK WATER TREATMENT PLANT

Entry Point: EP-B

Sample Period: July/2025
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less
than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

--- For DHS use only ---

Minimum Water Quality Parameters as set by

pH 7.0
Alk 36 (Alkalinity)
PO4 (Orthophosphate)
Sili (Silicate)

Print Name:

Signature:

Date:

Chad Marshall
8/6/2025

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381