

City of Corvallis

Water Quality Parameter Monitoring Form



Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N	
1	7.3				Y	
2	7.4				Y	
3	7.4	42			Y	
4	7.4				Y	
5	7.4				Y	
6	7.5				Y	
7	7.5				Y	
8	7.5				Y	
9	7.4				Y	
10	7.4	44			Y	
11	7.4				Y	
12	7.4				Y	
13	7.5				Y	
14	7.4				Y	
15	7.4				Y	
16	7.3				Y	
17	7.3	40			Y	
18	7.3				Y	
19	OFF					
20	OFF					
21	OFF					
22	OFF					
23	7.5				Y	
24	7.6	43			Y	
25	7.6				Y	
26	7.3				Y	
27	7.4				Y	
28	7.4				Y	
29	7.4				Y	
30	7.4				Y	
31	7.4	44			Y	
(No = N = Excursion)					Total N's	0

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 2 2 5 B

System Name: ROCK CREEK WATER TREATMENT PLANT

Entry Point: EP-B

Sample Period: December/2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

--- For DHS use only ---

Minimum Water Quality Parameters as set by

pH	7.0	
Alk	36	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Sili	<input type="text"/>	(Silicate)

Print Name:

Signature:

Date:

Chad Marshall
Chad Marshall
1/5/2025

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381