

City of Corvallis

Water Quality Parameter Monitoring Form



Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N	
1	7.3				Y	
2	7.2				Y	
3	7.2				Y	
4	7.2				Y	
5	7.2				Y	
6	7.3				Y	
7	7.2	43			Y	
8	7.3				Y	
9	7.3				Y	
10	7.3				Y	
11	7.2				Y	
12	7.2				Y	
13	7.2				Y	
14	7.2	40			Y	
15	7.2				Y	
16	7.2				Y	
17	7.2				Y	
18	7.2				Y	
19	7.3				Y	
20	7.3				Y	
21	7.3	41			Y	
22	7.3				Y	
23	7.3				Y	
24	7.3				Y	
25	7.3				Y	
26	7.3				Y	
27	7.3				Y	
28	7.1	42			Y	
29	7.2				Y	
30	7.2				Y	
31	OFF					
(No = N = Excursion)					Total N's	0

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 **0 0 2 2 5 B**

System Name: ROCK CREEK WATER TREATMENT PLANT

Entry Point: EP-B

Sample Period: January/2026
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

--- For DHS use only ---

Minimum Water Quality Parameters as set by

pH	7.0	
Alk	36	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Chad Marshall
Signature: *Chad Marshall*
Date: 2/6/2026