City of Corvallis

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 2 2 5 B

Day	pH	Alk	Phos	Other	Y/N
1	OFF				
2	OFF				
3	OFF				
4	OFF				
5	OFF				
6	OFF				
7	OFF				
8	OFF				
9	7.3				Y
10	7.3				Y
11	7.2	43			Y
12	7.2				Y
13	7.2				Y
14	7.3				Y
15	7.2				Y
16	7.2				Y
17	7.2				Y
18	7.2	42			Y
19	7.2				Y
20	7.2				Y
21	7.2				Y
22	7.2				Y
23	7.2				Y
24	7.3				Y
25	7.4	43			Y
26	7.2				Y
27	7.2				Y
28	7.2				Y

(No = N = Excursion) **Total N's** 0

System Name: ROCK CREEK WATER TREATMENT PLANT

Entry Point: EP-B

Sample Period: February/2026
Month/Year

Number of excursions* during this month: 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

---- For DHS use only ----

Minimum Water Quality Parameters as set by

pH	7.0	
Alk	36	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Chad Marshall

Signature: Chad Marshall

Date: 3/9/2026

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381