

City of Corvallis

Water Quality Parameter Monitoring Form



Lead & Copper Rule Corrosion Control

ENTRY POINT

Day	pH	Alk	Phos	Other	Y/N	
1	7.2				Y	
2	7.2				Y	
3	7.2				Y	
4	7.2	44			Y	
5	7.2				Y	
6	7.3				Y	
7	7.3				Y	
8	7.4				Y	
9	7.4				Y	
10	7.4				Y	
11	7.2	42			Y	
12	7.2				Y	
13	7.2				Y	
14	7.3				Y	
15	7.3				Y	
16	7.3				Y	
17	7.3				Y	
18	7.3	44			Y	
19	7.3				Y	
20	7.3				Y	
21	7.3				Y	
22	7.4				Y	
23	7.4				Y	
24	7.3				Y	
25	7.3	41			Y	
26	7.3				Y	
27	7.3				Y	
28	7.3				Y	
29	7.3				Y	
30	7.3				Y	
31	7.3				Y	
(No = N = Excursion)					Total N's	0

<< Have minimums been met for this day?

PWS ID: 41

0 0 2 2 5 B

System Name:

ROCK CREEK WATER TREATMENT PLANT

Entry Point:

EP-B

Sample Period:

March/2026

Month/Year

Number of excursions* during this month: **0**

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: **0**

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

--- For DHS use only ---

Minimum Water Quality Parameters as set by

pH **7.0**

Alk **36** (Alkalinity)

PO4 (Orthophosphate)

Sili (Silicate)

Print Name:

Signature:

Date:

Chad Marshall
Chad Marshall
4/6/26

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381