

City of Corvallis



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.3	40			Y
2	7.2	34			Y
3	7.3	34			Y
4	7.3				Y
5	7.3	36			Y
6	7.3	35			Y
7	7.3	38			Y
8	7.3	40			Y
9	7.3	44			Y
10	7.3	38			Y
11	7.3	40			Y
12	7.3	38			Y
13	7.3	36			Y
14	7.3	38			Y
15	7.2	37			Y
16	7.3	38			Y
17	7.3				Y
18	7.3	36			Y
19	7.3	40			Y
20	7.3	36			Y
21	7.3	36			Y
22	7.2	34			Y
23	7.3	34			Y
24	7.3	35			Y
25	7.3	38			Y
26	7.2	32			Y
27	7.2	34			Y
28	7.3	36			Y
29	7.2	36			Y
30	7.3	34			Y
31	7.3	40			Y

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 2 2 5 A

System Name: TAYLOR WATER TREATMENT PLANT
Entry Point: EP-A
Sample Period: March/2021
 Month/Year

Number of excursions* during this mon 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 mont 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk	24.9	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Tom Hubbard
Signature:
Date: 4-5-2021

(No = N = Excursion) **Total N's** 0

Send to DHS within 10 days after end of sampling period