

City of Corvallis



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.2				Y
2	7.2				Y
3	7.2	38			Y
4	7.2				Y
5	7.2	38			Y
6	7.2				Y
7	7.2	32			Y
8	7.2				Y
9	7.2				Y
10	7.2				Y
11	7.2	31			Y
12	7.2				Y
13	7.2				Y
14	7.2				Y
15	7.2	32			Y
16	7.2				Y
17	7.2				Y
18	7.2				Y
19	7.2	30			Y
20	7.2				Y
21	7.2	36			Y
22	7.2				Y
23	7.2	30			Y
24	7.2				Y
25	7.2	30			Y
26	7.2				Y
27	7.2				Y
28	7.2				Y
29	7.2				Y
30	7.2	30			Y
31	7.2				Y

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 A

System Name: TAYLOR WATER TREATMENT PLANT
Entry Point: EP-A
Sample Period: May/2021
 Month/Year

Number of excursions* during this mon 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 mont 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.0"/>	
Alk	<input type="text" value="25"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Sili	<input type="text"/>	(Silicate)

Print Name: Tom Hubbard

Signature: [Signature]

Date: 6-3-2021

(No = N = Excursion) Total N's

Send to DHS within 10 days after end of sampling period