

# City of Corvallis



Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
1	7.2				Y
2	7.3	32			Y
3	7.2				Y
4	7.3	30			Y
5	7.2				Y
6	7.2	31			Y
7	7.2				Y
8	7.2	32			Y
9	7.2				Y
10	7.2	31			Y
11	7.2				Y
12	7.2	30			Y
13	7.2				Y
14	7.2	30			Y
15	7.2				Y
16	7.2	32			Y
17	7.3				Y
18	7.3	36			Y
19	7.2				Y
20	7.2	33			Y
21	7.2				Y
22	7.3	30			Y
23	7.3				Y
24	7.3	32			Y
25	7.2				Y
26	7.2	33			Y
27	7.2				Y
28	7.2	33			Y
29	7.2				Y
30	7.2	32			Y

<< Have minimums been met for this day?

### ENTRY POINT

PWS ID: 41      A

System Name: TAYLOR WATER TREATMENT PLANT

Entry Point: EP-A

Sample Period: September/2022  
Month/Year

Number of excursions\* during this mon 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 mont 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

#### Minimum Water Quality Parameters as set by

pH	<u>7.0</u>	
Alk	<u>25</u>	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Chad Marshall

Signature: [Signature]

Date: 10/7/2022

(No = N = Excursion) Total N's 0

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381