

City of Corvallis



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.0				Y
2	8.0				Y
3	7.9				Y
4	7.8	38			Y
5	7.4				Y
6	7.3				Y
7	7.3				Y
8	7.2				Y
9	7.3				Y
10	7.3				Y
11	7.4				Y
12	7.2				Y
13	7.5				Y
14	7.8	40			Y
15	7.5				Y
16	7.5				Y
17	7.6				Y
18	7.5				Y
19	7.5				Y
20	7.5				Y
21	7.5				Y
22	7.4				Y
23	7.5				Y
24	7.5				Y
25	7.5	39			Y
26	7.5				Y
27	7.4				Y
28	7.3				Y
29	7.2				Y
30	7.4				Y
31	7.3				Y

(No = N = Excursion) **Total N's** 0

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

0 0 2 2 5 B

System Name: ROCK CREEK WATER TREATMENT PLANT

Entry Point: EP-B

Sample Period: January/2021
Month/Year

Number of excursions* during this mon 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 mont 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk	37.3	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Tom Hubbard

Signature: [Signature]

Date: 2-4-21

Send to DHS within 10 days after end of sampling period

DHS-Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (503) 731-4381