

City of Corvallis



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N	
1	7.6				Y	
2	7.7				Y	
3	7.5				Y	
4	7.5				Y	
5	7.5	40			Y	
6	7.5				Y	
7	7.4				Y	
8	7.5				Y	
9	7.5				Y	
10	7.5				Y	
11	7.5				Y	
12	7.5	42			Y	
13	7.4				Y	
14	7.5				Y	
15	7.6				Y	
16	7.5				Y	
17	7.4				Y	
18	7.5				Y	
19	7.6	43			Y	
20	7.6				Y	
21	7.7				Y	
22	7.7				Y	
23	7.7				Y	
24	7.6				Y	
25	7.7				Y	
26	7.7	42			Y	
27	7.7				Y	
28	7.5				Y	
29	7.8				Y	
30	7.7				Y	
31	7.7				Y	
(No = N = Excursion)					Total N's	0

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 2 2 5 B

System Name: ROCK CREEK WATER TREATMENT PLANT
Entry Point: EP-B
Sample Period: January/2022
 Month/Year

Number of excursions* during this mon 0

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 mont 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk	36	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Chad Marshall
Signature: *Chad Marshall*
Date: 2/2/2022

Send to DHS within 10 days after end of sampling period