

City of Corvallis



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.4				Y
2	7.4				Y
3	7.5	42			Y
4	7.6				Y
5	7.5				Y
6	7.4				Y
7	7.5				Y
8	7.5				Y
9	7.6	43			Y
10	7.6				Y
11	7.6				Y
12	7.7				Y
13	7.4				Y
14	7.4				Y
15	7.3				Y
16	7.4	42			Y
17	7.4				Y
18	7.4				Y
19	7.4				Y
20	7.4				Y
21	7.4				Y
22	7.4				Y
23	7.4	42			Y
24	7.5				Y
25	7.4				Y
26	7.4				Y
27	7.4				Y
28	7.4				Y
29	7.4				Y
30	7.4	43			Y
31	7.4				Y

<< Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 0 0 2 2 5 B

System Name: ROCK CREEK WATER TREATMENT PLANT
Entry Point: EP-B
Sample Period: March/2022
 Month/Year

Number of excursions* during this mon 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 mont 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

Minimum Water Quality Parameters as set by

pH	7.0	
Alk	36	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

Print Name: Chad Marshall
Signature: *Chad Marshall*
Date: 4-4-2022

(No = N = Excursion) Total N's 0

Send to DHS within 10 days after end of sampling period