

# City of Corvallis



## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3	42			Y
2	7.4				Y
3	7.4				Y
4	7.3				Y
5	7.2				Y
6	7.2				Y
7	7.3				Y
8	7.3	41			Y
9	7.3				Y
10	7.3				Y
11	7.3				Y
12	7.2				Y
13	7.2				Y
14	7.3				Y
15	7.3	42			Y
16	7.3				Y
17	7.2				Y
18	7.3				Y
19	7.4				Y
20	7.2				Y
21	Off				Off
22	Off				Off
23	Off				Off
24	Off				Off
25	Off				Off
26	Off				Off
27	Off				Off
28	Off				Off
29	Off				Off
30	7.3				Y

(No = N = Excursion) **Total N's** 0

<< Have minimums been met for this day?

### ENTRY POINT

PWS ID: 41 0 0 2 2 5 B

**System Name:** ROCK CREEK WATER TREATMENT PLANT  
**Entry Point:** EP-B  
**Sample Period:** June/2022  
 Month/Year

**Number of excursions\* during this mon** 0

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 mont** 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

#### Minimum Water Quality Parameters as set by

pH	7.0	
Alk	36	(Alkalinity)
PO4		(Orthophosphate)
Sili		(Silicate)

**Print Name:** Chad Marshall  
**Signature:** *Chad Marshall*  
**Date:** 7-7-2022

Send to DHS within 10 days after end of sampling period