

# City of Corvallis



Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.2				Y
2	7.2				Y
3	7.2	46			Y
4	7.2				Y
5	7.2				Y
6	7.2				Y
7	7.3				Y
8	7.2				Y
9	7.2				Y
10	7.1				Y
11	7.2				Y
12	7.2	48			Y
13	7.2				Y
14	7.2				Y
15	7.2				Y
16	7.2				Y
17	7.2	47			Y
18	7.2				Y
19	7.2				Y
20	7.2				Y
21	7.2				Y
22	7.2				Y
23	7.2				Y
24	7.2				Y
25	7.2	50			Y
26	7.2				Y
27	7.1				Y
28	7.1				Y
29	7.1				Y
30	7.1				Y
31	7.1				Y

<< Have minimums been met for this day?

### ENTRY POINT

PWS ID: 41

B

**System Name:** ROCK CREEK WATER TREATMENT PLANT

**Entry Point:** EP-B

**Sample Period:** August/2022  
Month/Year

**Number of excursions\* during this mon** 0

(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 mont** 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For DHS use only

#### Minimum Water Quality Parameters as set by

pH	<input type="text" value="7.0"/>	
Alk	<input type="text" value="36"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Sili	<input type="text"/>	(Silicate)

**Print Name:** Chad Marshall

**Signature:** *Chad Marshall*

**Date:** 9/6/2022

(No = N = Excursion) **Total N's**

Send to DHS within 10 days after end of sampling period