

Day	pH	Alk	Phos	Other	Y/N
1	7.4				Y
2	7.4				Y
3	7.4				Y
4	7.4				Y
5	7.4				Y
6	7.4				Y
7	7.3				Y
8	7.3				Y
9	7.3				Y
10	7.3				Y
11	7.4				Y
12	7.4				Y
13	7.4				Y
14	7.4				Y
15	7.5				Y
16	7.5				Y
17	7.5				Y
18	7.5				Y
19	7.5				Y
20	7.5				Y
21	7.5				Y
22	7.5				Y
23	7.5				Y
24	7.5				Y
25	7.5				Y
26	7.5				Y
27	7.5				Y
28	7.5				Y
29	7.5				Y
30	7.5				Y
31					

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: WESLINN WATER COMPANY

Entry Point: EP-A

Sample Period: _____
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Joe Anthony

Signature: [Signature]

Date: 10-6-21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's