

Day	pH	Alk	Phos	Other	Y/N
1	7.5				Y
2	7.5				Y
3	7.5				Y
4	7.5				Y
5	7.5				Y
6	7.5				Y
7	7.5				Y
8	7.5				Y
9	7.5				Y
10	7.5				Y
11	7.5				Y
12	7.5				Y
13	7.5				Y
14	7.5				Y
15	7.5				Y
16	7.5				Y
17	7.5				Y
18	7.5				Y
19	7.5				Y
20	7.6				Y
21	7.6				Y
22	7.7				Y
23	7.8				Y
24	7.7				Y
25	7.6				Y
26	7.5				Y
27	7.5				Y
28	7.5				Y
29	7.5				Y
30	7.5				Y
31					

(No = N = Excursion) Total N's

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: WESLINN WATER COMPANY

Entry Point: EP-A


Sample Period: November / 2021
 Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 

Alk (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: JOE Anthony

Signature: [Signature]

Date: 11/30/21

Send to DWP within 10 days after end of sampling period