

Day	pH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.7				Y
3	7.6				Y
4	7.6				Y
5	7.5				Y
6	7.5				Y
7	7.4				Y
8	7.4				Y
9	7.5				Y
10	7.5				Y
11	7.6				Y
12	7.6				Y
13	7.6				Y
14	7.6				Y
15	7.6				Y
16	7.6				Y
17	7.6				Y
18	7.6				Y
19	7.6				Y
20	7.6				Y
21	7.6				Y
22	7.6				Y
23	7.7				Y
24	7.7				Y
25	7.7				Y
26	7.7				Y
27	7.8				Y
28	7.8				Y
29	7.7				Y
30	7.7				Y
31					

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41

System Name: WESLINN WATER COMPANY

Entry Point: EP-A

Sample Period: Sept. / 2023  
Month/Year

Number of excursions\* during this month: 0  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Other  ( )

Print Name: Jody Anthony

Signature: Jody Anthony

Date: 10/2/23 - 541-990-9835

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's