

Day	pH	Alk	Phos	Other	Y/N
1	7.2				Y
2	7.2				Y
3	7.2				Y
4	7.2				Y
5	7.2				Y
6	7.2				Y
7	7.2				Y
8	7.1				N
9	7.1				N
10	7.1				N
11	7.1				N
12	7.1				N
13	7.1				N
14	7.1				N
15	7.1				N
16	7.1				N
17	7.1				N
18	7.1				N
19	7.1				N
20	7.1				N
21	7.1				N
22	7.0				N
23	7.0				N
24	7.0				N
25	7.0				N
26	7.0				N
27	7.0				N
28	7.0				N
29	7.0				N
30	7.0				N
31	7.0				N

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41

System Name: WESLINN WATER COMPANY

Entry Point: EP-A

Sample Period: August / 2024  
Month/Year

Number of excursions\* during this month: 24  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 24  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality Parameters as set by**

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Other  ( )

Print Name: Jody Anthony

Signature: [Signature]

Date: 9/10/24

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's