

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5				Y
2	7.5				Y
3	7.5				Y
4	7.5				Y
5	7.5				Y
6	7.5				Y
7	7.5				Y
8	7.5				Y
9	7.5				Y
10	7.5				Y
11	7.5				Y
12	7.5				Y
13	7.5				Y
14	7.5				Y
15	7.4				Y
16	7.4				Y
17	7.4				Y
18	7.4				Y
19	7.4				Y
20	7.4				Y
21	7.4				Y
22	7.4				Y
23	7.4				Y
24	7.4				Y
25	7.4				Y
26	7.4				Y
27	7.4				Y
28	7.4				Y
29	7.4				Y
30	7.4				Y
31	7.4				Y

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00230

System Name: WESLINN WATER COMPANY

Entry Point: EP-A

Sample Period: December/2024
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.2 
Alk — (Alkalinity)
PO4 — (Orthophosphate)
Other — ()

Print Name: Jody Anthony
Signature: Jody Anthony
Date: 1/24/25

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's

0