

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.6				Y
2	7.6				Y
3	7.6				Y
4	7.6				Y
5	7.6				Y
6	7.6				Y
7	7.6				Y
8	7.6				Y
9	7.6				Y
10	7.6				Y
11	7.6				Y
12	7.6				Y
13	7.6				Y
14	7.6				Y
15	7.5				Y
16	7.5				Y
17	7.5				Y
18	7.5				Y
19	7.5				Y
20	7.5				Y
21	7.5				Y
22	7.5				Y
23	7.5				Y
24	7.4				Y
25	7.4				Y
26	7.4				Y
27	7.5				Y
28	7.5				Y
29	7.5				Y
30	7.5				Y
31					

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 00230

System Name: WESLINN WATER COMPANY

Entry Point: EP-A

Sample Period: April / 2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.2 =
Alk — (Alkalinity)
PO4 — (Orthophosphate)
Other — ()

Print Name: Jody Anthony

Signature: Jody Anthony

Date: 4/30/25 (541) 990-9835

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0