

Day	pH	Alk	Phos	Other	Y/N
1	7.56				Y
2	7.56				Y
3	7.56				Y
4	7.56				Y
5	7.56				Y
6	7.56				Y
7	7.56				Y
8	7.56				Y
9	7.56				Y
10	7.56				Y
11	7.56				Y
12	7.57				Y
13	7.58				Y
14	7.60				Y
15	7.62				Y
16	7.65				Y
17	7.65				Y
18	7.66				Y
19	7.66				Y
20	7.66				Y
21	7.66				Y
22	7.66				Y
23	7.66				Y
24	7.66				Y
25	7.66				Y
26	7.66				Y
27	7.65				Y
28	7.64				Y
29	7.64				Y
30	7.63				Y
31	7.63				Y

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 00230

System Name: WESLINN WATER COMPANY

Entry Point: EP-A

Sample Period: March/2021
Month/Year

Number of excursions* during this month: 0
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
Alk	<u>—</u>	(Alkalinity)
PO4	<u>—</u>	(Orthophosphate)
Other	<u>—</u>	()

Print Name: Jody Anthony

Signature: [Signature]

Date: 3-31-21

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0